

Questions received and responses:

Question - I'm enquiring about BID no 73225. Regarding the mobile generators, should our supplies be exactly the same or are we allowed leeway in terms of what we can supply.

Further in the case that we cannot supply based on the specifications given by the BID documentation. Can we also submit brochures and written reports on to why we submitted the bid as was.

Answer - We are looking for the specified one, submit what you have got it might be considered.

Question - Top page stipulate 180kVA and specifications 150kVA with a 150kVA kW description.

It also cannot be a 150 Prime / 180kVA Standby, because 150 Prime kicks out 165kVA Standby Power.

Answer - It's a typo, it should have been 150kva.

Question - I am kindly requesting clarification regarding the above-mentioned bid on the following points:

- Could you kindly confirm whether Item 3 is for an 8 kVA mobile generator or an 8 kVA mobile lighting tower? The listed specifications (mast height, LED lamps, wind stability, etc.) appear to correspond to a mobile lighting tower.

Answer - It's a lighting tower which must also have plug points for single phase.

Question - Could you kindly confirm whether the 500 kVA generator is required to provide both 400 V and 480/220 V outputs as standard, or whether this may be achieved through a voltage selector or transformer?

Answer - It must be able to produce both 400v and 220v.

Question - Could you kindly confirm whether the required 24-hour runtime may be achieved using an external bulk fuel tank, or whether the base fuel tank alone must provide a minimum runtime of 24 hours at 100% load?

Answer - The only generator that will be using external bulk fuel tank is a 500KVA

Question - Could you kindly confirm whether all trailer-mounted units must be supplied fully registered and licensed for road use, with the relevant trailer registration documentation included in the bid?

Question - Could you kindly specify the PPE items required under the Bill of Quantities, as the tender does not indicate the type or contents of the PPE sets.

Answer - Normal PPE that is used when servicing the generator like clothing, gloves and glasses etc.

Question - Could you kindly clarify which permits are required under the Bill of Quantities?

Answer - Acsa permit.

Question - Could you kindly confirm whether the generators are required to be supplied on undercarriages (trailer-mounted), or if this requirement applies only to the mobile lighting tower?

Answer - Trailer mounted.

Question - Could you kindly confirm whether the pricing should include offloading, rigging into position, and connection of the generators to the electrical supply?

Answer - We are not sure how you are going to supply them, but if it needs rigging please include it on the quote and connection and demonstration will be required for 500kva

Question - We noticed that the bid calls for the supply of units for 12 months, does that mean it will be a rental agreement? There is also a discrepancy between the NEC and the Tender Document in the name of the Bid.

Answer – the title has been corrected on the tender document and we have issued an addendum.

Question - The 150kVA and 500kVA generators are specified to be Mobile, however these generators cannot be mobile generators as advised by the manufacturers. May you kindly confirm the correct specification.

Answer - Please note that this is not for rental but purchase, the reason for 12 months is to give suppliers time to acquire those units and also they need to service them before the end of the twelfth month.

Question - The bid is being submitted on both Etenders and on Email, or we need only follow what is set out in the document?

Answer – Email submissions to acsarfq@airports.co.za

Question - Could you kindly confirm whether each generator is required to have its own dedicated trailer, or whether multiple generators may be transported using a shared trailer?

Answer - Each trailer must have its own trailer preferably mounted.

Question - Could you kindly confirm whether each generator is required to have its own dedicated trailer, or whether multiple generators may be transported using a shared trailer?

Answer - Each trailer must have its own trailer preferably mounted.