

To whom it may concern

Date:

16 January 2025

Enquiries:

Tel +27 82 327 9650

Dear Supplier,

**INGULA PUMP STORAGE SCHEME STATION NON-DESTRUCTIVE EXAMINATION ON
WATERWAY 1/2 AND 3/4 PENSTOCK
ENQUIRY NO. WCPK1235MP**

- 1) **Supplier's Request:** Kindly indicate whether both waterways $\frac{1}{2}$ and $\frac{3}{4}$ penstocks will be dewatered simultaneously and made available for inspection at the same time?

Eskom Response: No, unit 3 and 4 gets dewatered first and the inspections get done on these 2 legs. Later in the year, approximately June 2025, unit 1 and 2 goes down and those 2 legs get inspected. There planning is for 2 visits.

- 2) **Supplier's Request:** Will UT inspection be required on the manholes?

Eskom's Response: Yes, that is correct as per scope of work.

- 3) **Supplier's Request:** Will scaffolding be accessible in both the bifurcations and penstocks at the same time?

Eskom's Response: Yes, the bifurcation and the penstock will have separate scaffolding.

Yours sincerely



Madelaine Prinsloo
Official Procurement