

	CLARIFICATION	Unique Identifier	
		Revision	0
		Effective Date	November 2015
		Page	1 of 1
		Tactical Procurement	

Date: 2022/04/12
 Enquiries: M Prinsloo
 Tel: 082 327 9650
 017 799 3435
 Email: PrinsIMA@eskom.co.za

Dear Sir / Madam

MAJUBA FIRE DETECTION MONITORING SYSTEM UPGRADE
ENQUIRY NO: MPGXC006521
MAJUBA POWER STATION

Clarification requested by suppliers, together with Eskom's response:

1. FSC – What is meant by 1 way, 2 way etc.? Can we install a fire panel in it's place that will do the control and signals to the HMI?

Yes, Eskom expects a functional fire detection system in line with the scope of work

2. Gas Suppression supply – on the clarifications there are only 4 rooms – do we still quote on all 7 as per the Price List?

There are 6 areas as clarified in a previous question

3. Gas Suppr supply tab (Pricelist) From Bill No. 8 – Bill No. 46 – For each room an ASD and a Conventional Alarm System is required. Is there gas suppression in each of these rooms? Can we connect the ASD's to our Fire Panels as they are approved for extinguishing as well?

A correction is made to the pricelist. Yes, so as long as this would comply with our existing standards.

4. Gas Suppr installation tab (Pricelist) From Bill No.8 – Bill No.46 - Pipework pressure test and Room integrity test are required in these rooms, although we do not do any gas installation work in these rooms. Is this still required? There is no mention of fire stopping. Will this be done on a CE basis, as this is not possible to price?

Not required if no gas suppression is installed. If ASD is used in specific instances, these tests may be required. Please price all other requirements in 'Other'.

Yours faithfully,



M Prinsloo
Official Procurement

