

Scope of work

Service and Calibration of safety valves

Perform servicing and calibration of 20 various air Pressure Release Valves(safety valves) a mouth and the supply of copper sealing gaskets where required, Pressure Release Valves to be serviced and Calibrated include mainly but not limited to Leser and Etna manufactured types of Pressure Release Valves, with the pressure ranges between 1-300 bars the service provider shall provide the following documentation:

- Process Quality Plan
- Service and calibration Report
- Service and Calibration Certificate endorsed by an Approved Inspection Authority.

Compiled by

BG Mbuli 1384791

A handwritten signature in black ink, consisting of a large, stylized capital 'B' followed by a capital 'M' and a capital 'B', with a horizontal line extending to the right.