

	Tender Questions and Answers	Document Identifier	559-222407715	Rev	1
		Effective Date	July 2024		
		Review Date	July 2027		

To whom it may concern	Date	16 July 2025
	Enquiries	Didimalang Motsemme
	E-mail address	MotsemD@ntcsa.co.za

Dear Sir/Madam

Request for Enquiry Number	E1442NTCSA-CSMWP
Description / Project Title	The manufacture at works, testing, inspection, supply, packaging and quality assurance of estimated quantities of indoor and outdoor AC Distribution Boards and outdoor Junctions Boxes to be used in various NTCSA Substations, on an “as and when” required basis, for a period of five (5) years
Tender Questions Closing Date	05 August 2025 at 10h00

Item	Questions	Answers	Clarity Published Dates
1.	**Technical** 1. **Purchaser Goods Information (Standard 240-76628687 and Transmission Junction Boxes): ** * **SAP Number 603532: ** The description indicates a 400V AC DMK Type 4, but Drawing 0.54/6729 and Standard 240-76628687 (page 13-14, Point 7- Drawings) indicate it's a Type 1. Please confirm that Drawing 0.54/6729 is correct for SAP number 603532.	1. *Drawing number 0.54/6729 is the correct drawing for SAP number 603532 item.	24 July 2025

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of NTCSA SOC Ltd, © copyright NTCSA SOC Ltd, Reg No 2021/539129/30

	Tender Questions and Answers	Document Identifier	559-222407715	Rev	1
		Effective Date	July 2024		
		Review Date	July 2027		

	* **SAP Number 603520: ** Please provide a drawing for Eskom SAP number 603520, BOX, Distr: 230V AC DMK Type 4; WD 600mm. 2. **Technical Standard 240-64139144 (Transmission Junction Boxes, Eskom SAP Number 603522): ** There is a discrepancy between the technical standard and the drawing. The equipment listed on Technical Standard 240-64139144 - Annex M- Technical A/B Schedule for TDB Type 2, Page 40, does not match the TDB Type 2 drawing number 0.52/20253. Please clarify this discrepancy.	*Drawing number for SAP number 603520: BOX, Distr: 230V AC DMK Type 4; WD 600mm is 0.54/7106. 2. TDB stands for Transformer Distribution Board. Drawing number 0.52/20253 title Type 2 Transformer Distribution Board is the correct drawing for SAP number 603522: TDB Type 2. Annex M- Technical A/B Schedule for TDB Type 2 specifies this drawing number 0.52/20253 for casing construction.	
2.	**Financial** 1. **PS5 Pricing Schedule- Manufacture Testing Supply and Packaging of Junction Boxes:** The tender states that the supplier is responsible for transportation to various purchaser sites, but these sites are not specified in any tender document. Given that the items have different dimensions and weights, this complicates providing pricing data for transport. Please provide the "Transport Schedule" that the tenders have to update.	Even though it was said in the Clarification Meeting on 21 July 2025 that the suppliers are to provide transport and the "transport schedule" will be shared on the Tender Bulletins, the business has taken a decision to continue with Rotran (ERI) providing transportation. This is due to the fact that certain requirements (e.g. Safety) were exempted as a result of transport being provided by Rotran.	24 July 2025

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of NTCSA SOC Ltd, © copyright NTCSA SOC Ltd, Reg No 2021/539129/30

	Tender Questions and Answers	Document Identifier	559-222407715	Rev	1
		Effective Date	July 2024		
		Review Date	July 2027		

		The NEC document has been amended. Delivery to site or stores and off-loading have been removed from the NEC. On the tender document, kindly disregard.	
--	--	---	--

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of NTCSA SOC Ltd, © copyright NTCSA SOC Ltd, Reg No 2021/539129/30