



BID 1-2024

**DYSELSDORP: KASPER BOERDERY: INSTALLATION OF 6HA PERMANENT
IRRIGATION SYSTEM, SOLAR PANELS PLUS SUBMERSIBLE PUMP AND CAMP
FENCING**

JULY 2024

ADDENDUM 1 TO ABOVE BID CLOSING ON 25nd JULY 2024

The following clauses are to be added to cdb 3

RETENTION	Retention is 10% of contract sum for 3 months not bearing interest, with no upper limit.
PENALTY CLAUSE	The penalty R 1 500.00 calendar day will be applied for late completion of works.
REVISED CLOSING DATE	The revised closing date will be 7 th August 2024

Changes / Extras to be priced

1. The correct material list is attached.
2. The position of the Solar structure needs to be changed to the bottom of the embankment and not on top of the embankment as was shown out on site. Allow for a distance of approximately 35 metres of cabling between the structure and the pump position inside the river.
The solar structure must be built on a height of 3 metres above natural ground level. The concrete bases need to be buried 500mm below ground level. Sizes of the bases must be 600 x 600 x 600mm High for each post. Allow must be made for shuttering as the work proceeds.

Tenderers to acknowledge receipt of this addendum by signing the below form. This form must be submitted as part of his/her Bid.

Name of Company: _____

Address: _____

Telephone Number: _____

Fax Number: _____

Signature: _____

Date: _____

For office use only	Version no: 1	Date: 20 January 2014
To be signed upon appointment of winning bidder to form the agreement between the parties		
Signature for Casidra		Signature for Contractor