

MHLATHUZE WATER
CONTRACT NO MW/83/3/2022/2023 and MW 84/3/2022/2023
CONTRACT 3-1: CONSTRUCTION OF 2.8KM OF DN1500 CONTINUOUSLY WELDED
STEEL PIPELINE



MHLATHUZE WATER

ADDENDUM No. 1

CONTRACT NUMBERS	DESCRIPTION
MW/83/3/2022/2023 AND MW 83/3/2022/2023	CONTRACT 3-1: CONSTRUCTION OF 2.8KM OF DN1500 CONTINUOUSLY WELDED STEEL PIPELINE and CONTRACT 3-2: CONSTRUCTION OF 1.7KM OF DN1500 CONTINUOUSLY WELDED STEEL PIPELINE

The tenderer's attention is drawn to the tender documents for the above contracts. Tenderers are to note the following:

1 TENDER CLOSING

The Tenders Closing Date has been revised from Monday 24th April 2023 to Wednesday 26 April 2023. The tender closing time remains the same as stipulated in the tender documents.

2 TENDER CLARIFICATIONS

The deadline for Request for Clarification has been moved/ extended to Friday 19th April 2023. In addition to the contact stipulated in the Tender Documents, tender queries should be emailed to tender@mhlathuze.co.za

MHLATHUZE WATER
CONTRACT NO MW/83/3/2022/2023 and MW 84/3/2022/2023
CONTRACT 3-1: CONSTRUCTION OF 2.8KM OF DN1500 CONTINUOUSLY WELDED
STEEL PIPELINE

3 TENDER SUBMISSION

CLARIFICATIONS

Clarification 1: Please provide the Electronic Bill of Quantities (BOQ) for Contracts MW83/3/2022/2023 & MW82/3/2022/2023.

The electronic BOQ has been uploaded to the following link.

[Nsezi Raw Water Augmentation MW83 & MW82](#)

It is the onus of the Tenderer to ensure that the Electronic BOQ corresponds with that of the actual tender document. The Tendered BOQ is to be handwritten into the tender Document, and this value will be carried through to the Form of Offer, C1.1.

The tenderer is to submit a priced excel BOQ with their tender submission.

Clarification 2: Are wayleaves available for Transnet & Eskom?.

Yes, these wayleaves are available and have been secured by the project team. It is the Contractors responsibility to ensure that the requirements for the wayleaves are met as per the applicable documentation. The Tenderer is to ensure that all applicable requirements for the wayleaves are included in the tendered rates.

Clarification 3: Please confirm if cathodic protection is included in the contract?.

Yes, a provisional sum has been included for the Cathodic Protection design and installation. The Tenderers are to include the cathodic protection design and installation in the tendered programme.

Clarification 4: Confirm free issue pipe on the Contract MW83/3/2022/2023 (Contract 3-1)?.

DN1500 steel pipeline is available as free issue on this contract as indicated in the project specifications and BOQ.

Clarification 5: Confirm free issue pipe on the Contract MW82/3/2022/2023 (Contract 3-2)?.

MHLATHUZE WATER
CONTRACT NO MW/83/3/2022/2023 and MW 84/3/2022/2023
CONTRACT 3-1: CONSTRUCTION OF 2.8KM OF DN1500 CONTINUOUSLY WELDED
STEEL PIPELINE

The Contractor will be required to supply 936m of DN1500 steel pipe under this contract. The remaining length of pipe will be issued as free issue to the Contractor. The Contractor is to include the associated timeframes with the supply and installation of steel pipelines in the tendered programme.

Clarification 6: Confirm why the OHS BOQ is prescriptive?

The OHS BOQ has been developed as per MW requirements, Baseline Risk Assessment and OHS Specifications. Any additional items required by the Contractor are to be priced in the BOQ under "Other (Contractor to specify)". Any additional items required by the Contractor will be deemed included in the tenderized rates.

Clarification 7: Confirm free issue material?

DN1500 steel pipeline is supplied on contract 3-1 and 3-2 as per clarification 4 & 5 above. Tenderers are to note if an item does not state "free issue" in the document then it is required to be procured, supplied, and installed. Tenderers are to note that bends can be fabricated for the DN1500 pipeline from the free issue material.

Clarification 8: Confirm if the access road is to remain operational?

Yes, the existing access road is to remain operational at all times. The Tenderers are to ensure the applicable traffic accommodation is undertaken throughout the contract and deemed included in the tendered rates. The Contractor has to work in a manner to ensure that the road remains open during the duration of construction. The tenderer is to take particular note of restricted working conditions due to the working corridor, access road & services and ensure this is included in the tendered rates.

4 ADDENDUM ACKNOWLEDGEMENT

The tenderer, _____

MHLATHUZE WATER
CONTRACT NO MW/83/3/2022/2023 and MW 84/3/2022/2023
CONTRACT 3-1: CONSTRUCTION OF 2.8KM OF DN1500 CONTINUOUSLY WELDED
STEEL PIPELINE

(Name of Tenderer)

hereby confirms receipt of **Addendum No.1** for Contract Number MW/83/3/2022/2023 and MW 83/3/2022/2023 and confirms that he/she understands the contents of this Addendum by signing herewith and which to be included in the Tender Submission.

This submission is to be signed and emailed to tender@mhlathuze.co.za in addition to being included in the Tender Submission.

Failure to Acknowledge this Addendum will lead to the rejection of the tender.

Signed on Behalf of the Tenderer	
Name of Authorized Representative	
Designation of Authorized Representative	
Date	

MHLATHUZE WATER
CONTRACT NO MW/83/3/2022/2023 and MW 84/3/2022/2023
CONTRACT 3-1: CONSTRUCTION OF 2.8KM OF DN1500 CONTINUOUSLY WELDED
STEEL PIPELINE