

CLARIFICATION No. 1

Date: 11.08.2023

Ref: Clarification 1

Enquiries: Thabile Sibiyi

Tel: 031 710 5396

Email: sibiyaTh@eskom.co.za

To whom it may concern

RE: KZN093

THE MANUFACTURE, SUPPLY AND DELIVERY OF THREE (3) SETS OF TAPCHANGER SPARES FOR VARIOUS PLANT/STRATEGIC SPARES TO BE DELIVERED TO CATO RIDGE TRAINING CENTRE IN THE KZN OPERATING UNIT AS A ONCE OFF ORDER.

Item	Clarification/Query	Response
1.	We require the following information on the UZ. 1. Serial number 2. Counter reading if available	Ferranti DS2 - A_100311875 ATL AT317 - 80023/3 ASEA UZCRN 250/300 - 2215786
2.	With regards to the UZ tap changer spares. We also need to know which drive shafts you are referring too. As the info on the oltc we note that the unit has a reversing switch and is a neutral type oltc. Can you inform on which you are looking for as the description only mentions "2 x Sets Asea UZCRN Drive Shafts - 2 Long + 1 Short Per Set " which could be either for the reversing or main drive shafts couplings or are they referring to the insulated drive shaft (53) or steel drive shafts(53A)	The drive shafts being referred to are the "steel drive shafts (53A)" below. The short shaft is from the Geneva wheel to the first set of contacts and the two long shafts are from the first to second and second to third sets of contacts.



