



Technical Evaluation Criteria
Supplying and Delivery of Breaker Test instrument (132kv and 400kv Voltage testers)

Tender

		Evaluation Criteria for breaker test instrument (132kv and 400kv Voltage testers)	
Number	Criteria Description	Evidence	Weighting
1	1.1 Voltage Testers powered by 9v Batteries 1.2 Bright high intensity red LED's provide clear visual Bullet even in unfavourable daylight 1.3 Must have Self-test button to test battery and proper functioning of HV detector.	Supply to confirm by submitting the correct specification document for Voltage testers	50%
2	Previous experience	Submit proof inform of letter or an order delivering the product to any client.	20%
3	Product Picture	Submit a picture of the Voltage Detector with voltage rating 132Kv and 400kv	20%
4	Approval certificate by manufacture done on standard IEC 61243-5	Supplier to submit that the voltage testers will be procured by manufactures accredited by IEC 61243-5	10%
Threshold			100%
Total			100%

Name	Mduduzi Mkhabela	
Designation	Supervisor	
Date	24 July 2025	
Signature		