



LANDBOUNAVORSINGSRAAD

Private Bag X1251, Potchefstroom, 2520, South Africa
114 Chris Hani Drive, Potchefstroom, 2531
Lesegot@arc.agric.za Website: www.arc.agric.za

Ref: Tender ARC52/01/2025

Enquiries/Navrae: Lesego Theebeatshipi

11 March 2025

ATTENTION: TO ALL BIDDERS WHO ATTENDED THE COMPULSORY BRIEFING SESSION

TENDER NO ARC/52/01/2025: SUPPLY, DELIVERY AND NEW INSTALLATION OF THE PERIMETER FENCING FOR THE AGRICULTURAL RESEARCH COUNCIL, GRAIN CROPS, POTCHEFSTROOM.

The following correction is hereby brought to the attention of the prospective bidders.

Bid Document

All references to concrete pipes in the bid document are deleted in its entirety.

Mandatory requirements

Paragraph 1 of the mandatory requirements: Bidders must have a CIDB contractor grading designation of 4SQ or higher. Submit proof of valid CIDB registration.

Paragraph 2 of the mandatory requirement is removed from the specifications in its entirety.

BOQ

Item number 15: Storm water pipe installation is removed from the BOQ.

Item number 16: deletion of the words pipe on the description.

Note to the bidders:

1. Thickness of the fencing: 5mm.
2. 17 pieces in between the posts (in panel)
3. Number of panels: 1220
4. Panel: 3m
5. Corners: 8
6. Number of posts: 2440
7. Quality of the steel : polycoated
8. Expansion joints: two in every 20m
9. Box: 600mm x 600mm X 600mm

10. Shark teeth spikes: to cover 3650m or 1220 panels
11. Total height: 3.3m above NGL (excluding concertina razor wire).
12. Service provide to make provision for the storage of material.
13. Service provider to submit current and valid public liability insurance from the accredited insurer (letter of intent will not be accepted).
14. Bricks: Burnt clay facebrick and must conform to SABS 227, imperial size. Service provider must provide cost breakdown for sand, cement, reinforcement etc.
15. Steel reinforcement cage: refer to number 12 of the BOQ.
16. Figure number 3 is for illustration purposes, for the trench bidders to refer to number of the BOQ.

Closing date

Extension of closing date to 27 March 2025.

Hope you find the above in order.

Yours faithfully



.....
Ms. L Theebeatshipi
Supply Chain Accountant
Date: 11 March 2025

ACCEPTANCE AND INCORPORATION OF ADDENDUMS

I/ We accept Addendum No 1 forms part of the tender documents, and we confirm that we have noted the contents of this addendum.

- Have incorporated the amendments and additions contained in this addendum in my /our tender **ARC/52/01/2025.**

CONFIRMATION OF RECEIVING ADDENDUM NO.1 AND RECEIVED BY

Company name: _____

Name of Representative: _____

Signature: _____

Date: _____

NOTE: The signed confirmation and issued addendum must be submitted along with the bid document

For any clarity feel free to contact the Supply Chain Management Office by email to Lesegot@arc.agric.za
