

	BID CLARIFICATION	Form No: RW SCM 00041 F Revision: 03 Effective Date: 31 Jan 2023
---	----------------------------	--

Bid Number 10390779
Clarification Number 01

Enquiries: Lorraine Chauke
Direct Line: 011 682 0635
E-mail: Lcahuke@randwater.co.za
Date: 17 March 2023

BID NUMBER :10390779

BID DESCRIPTION– Renovations of residential properties at Rand Water Zuikerbosch, Zwartjoppjes and Central Depot

Based on the Non-compulsory Site meeting held on the 14th of March 2023. The below listed questions were received which required a clarification.

The pages referenced are the pages of the 1039779 bid document.

This clarification consists of three statements in the following pages.

SIGNATURES

**Buyer Name : :
LORRAINE CHAUKE**

Sign :

**Sourcing Manager Name
KULANI SHIBAMBU**

Sign :

**Supply Chain Manager Name :
EMMANUEL NZILO**

Sign :

**End User's Designation Name :
SELLO TLOU
CLEOPAS CHITAKA**

Sign :

Sign :

A. ENQUIRIES RELATED TO THE SCOPE OF WORK FOR THE SWIMMING POOL

- Bidders wanted clarity on the dimensions of the Tanks for the sand.
 - a) Tank capacity = 4.2m³ per tank.
- Bidders wanted clarity on the type of sand to be quoted.
 - a) Filter Sand (Course)
 - b) Filter Sand (Fine)
- Bidders wanted clarity on the quantity of the sand to be quoted.
 - a) Filter Sand (Course) = 2 x 1.5m³
 - b) Filter Sand (Fine) = 2 x 1.5m³

NB: Zuikerbosh drawings dimensions are in inches and in feet.

- a) 1' is an inch = 25mm
- b) 1" is a foot/feet and is equal to 300mm.

B. ENQUIRIES RELATED TO THE SCOPE OF WORK FOR THE SWIMMING POOL


- Bidders requested for the clear specification of the defects on the roof.
Possible defects on the roof might be.
 - a) Tiles that moved out of position.
 - b) Cracked tiles.
 - c) Cracks on the ridges area.
- Bidders required us to confirm the duration of the project.
 - a) Maximum estimated duration for this project is three Months for Zuikerbosch.

C. ENQUIRIES RELATED TO THE SCOPE OF WORK FOR CENTRAL DEPOT – WALL PAPERS

Below is the example of the type of wall paper that is required.

	BID CLARIFICATION	Form No: RW SCM 00041 F Revision: 03 Effective Date: 31 Jan 2023
---	----------------------------	--

Wall Paper Code



Wall Paper Type

