

	Tender Questions and Answers	Document Identifier	559-222407715	Rev	1
		Effective Date	July 2024		
		Review Date	July 2027		

To whom it may concern	Date	<u>19 July 2024</u>
	Enquiries	<u>Busi Rozani</u>
	E-mail address	<u>rozanib@ntcsa.co.za</u>

Dear Sir/Madam

Request for Enquiry Number	<u>KZN147</u>
Description / Project Title	The supply and delivery of trench covers for various substations in Transmission East Grid
Tender Questions Closing Date	<u>07 August 2024</u>

Item	Questions	Answers	Clarity Published Dates
1.	Can alternative materials (polymer) be offered?	The technical criteria does not cater for the evaluation of a polymer design. It is specific to concrete in that it requires and MPA value and mix design of the concrete as stipulated by quality. Further to this, the dimensions of the polymer design are shorter in length.	19 July 2024
2.			
3.			
4.			
5.			

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of NTCSA SOC Ltd, © copyright NTCSA SOC Ltd, Reg No 2021/539129/30

	Tender Questions and Answers	Document Identifier	559-222407715	Rev	1
		Effective Date	July 2024		
		Review Date	July 2027		

6.			
7.			

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of NTCSA SOC Ltd, © copyright NTCSA SOC Ltd, Reg No 2021/539129/30