

Request for Proposal – RFQ/26/27/86
Electrical Maintenance for Schweizer-Reneke Post Office

Bidders are encouraged to submit clarification questions in writing to South African Post Office Officials mentioned below not later than 2026/10/09 @ 09:00

#	QUESTION	RESPOND
1	Bidder has concerns about the tender briefing we had in Schweizer Reneke. Concerns are more on the COC side of the installation as we are being told only to fix a portion of the post office electrical works and leave the recessed light fittings, Air-cons and the front portion of the building out of the scope of works. So I don't understand that as the main DB supplies power to all of those circuits faulty or not and we must issue a COC in such conditions. Please clarify for me how according to standard I must only focus on one portion of the DB and ignore the other without making sure the whole installation is up to standard. If possible please relook at the BOQ and see that this will contradict any COC that will be issued onsite it will make the COC unlawful and might put people under huge scrutiny.	Refer to the Bill of Quantity for requirements. - The DB box must be upgraded. - All circuits be replaced. The back part of the building was rented previously be Telkom. All the electrical cables in that section was stolen. Circuit must be replaced but switch off that are providing electricity to all parts that is not mentioned, to be fixed. - Only the plugs and lights on the inside the Post Office was mentioned, that is the mostly important and must be fixed, because of finance.