

Clarification Questions and Answers: Bellville PO

After studying your RFQ document and attending the site meeting, we have the following clarification questions:

- 1) Within your objectives you correctly mentioned “replacement of submersible pumps”, however within BOQ/Pricing Schedule there is no mention of such which is a needed specification and cost matter = **Cost of pump falls under 1.1 on pricing schedule, all inclusive.**
- 2) What is the Kilowatt (kW) size of the pump you require? = **Supplier to match existing/quote based on site assessment.**
- 3) The RFQ document only refers to replacement of Gen cap cables and distribution; however, we are not certain if the Generator itself is in working condition = **The generator was in a working condition, however was not serviced.**
- 4) The existing gate motor is a gate motor for residential gate use, and the correct and long terms use of a proper commercial gate motor is advised. Should we replace it with a new proper gate motor for the existing heavy steel gate, will our higher cost influence our tender submission? = **Quote on a D5 motor. The gate size is similar to residential. No need for a commercial motor type.**