
**MTK 04/2026 – PROCUREMENT OF A GENERATOR HV CABLE
ADDENDUM 01**

ADDENDUM NO. 01

This Addendum is issued in terms of the Tender Data and must be read in conjunction with and shall be deemed to form part of the Tender Document. The Revised tender document will be issued in conjunction with this Addendum

The following items form part of ADDENDUM NO. 01

- **Clarifications to tenderers' enquiries,**
- **Tender Closing Date Extension**

Part 1: RESPONSE TO TENDER'S ENQUIRIES.

No.	ENQUIRY	RESPONSE
1	Clause 23: Scope of Work states Mintek will accept the delivery of the cable once necessary tests have been passed with the cable in position (Very Low Frequency (VLF) testing. The tender furthermore stipulates that "The bidder shall also include labour for laying the cable in a trench (excluding termination)" In order to do proper VLF testing, the terminations at both ends of the cable needs to complete. By excluding the termination from the scope of work, who will take responsibility for the cable after installation if the contractor doing the termination damages the cable. How do you proof if the damage was a result of poor cable installation or poor termination installation? We recommend that the terminations forms part of this tender	We would like to include cable termination on both ends of the cable as part of the scope so that the supplier of the cable takes full responsibility for the integrity of the cable. Please refer to the amended scope of work on the revised tender document. Addendum and revised tender documents have been issued.

2	The request to include a Pr. Tech as the same weight as a Pr. Eng	Because of the magnitude of the whole project, Mintek requires only a Professional Engineer to approve this part of the project (11 kV cable integrity certification).
---	---	--

Part 2: Tender Closing Date Extension

- Please note that the tender closing date has been extended from **24 August 2026 to 08 September 2026 at 12pm.**
- The closing date for all tender related queries is 26 August 2026 at 3pm.
- No late submissions will be accepted.
- The revised tender document issued in conjunction with the addendum.