The Petroleum
Oil and Gas Corporation
of South Africa SOC Ltd
Reg. No. 1970/008130/07
151 Frans Conradie Road,
Parow, 7500
Private Bag X 5 Parow, 7499
Republic of South Africa
Tel +27 21 929 3000
Fax +27 21 929 3266

TENDER BULLETIN 3

ENQUIRY NO: CTT0000027128
DESCRIPTION: Mechanical Demolition of Redundant Storage Tanks (Voorbaai) – Request for Drawings and Clarifications

Find below the Minutes of the site meeting that took place on 5th November 2026 @ 10h00 at the PetroSA Voorbaai Tank Farm

PetroSA
MINUTES OF THE SCOPE CLARIFICATION MEETING
Tender No.: CTT0000027128
Description: Demolition of Tanks Services for PetroSA, Voorbaai Tank Farm

Item	Details
Time	10h00am
Meeting No.	01
Meeting Date	05 November 2026
Convenor	V. Gumede
Scribe	V. Gumede

Apologies
Representatives from other companies were unable to attend due to access permit challenges.
Distribution
All Tenderers.

---

1. Welcome

1.1
Tenderers were welcomed to the meeting and introductions were conducted.

1.2
Following the introductions, attendees proceeded to the tank farm area to discuss the technical aspects of the tender and inspect the tanks identified for demolition.

---

2. Scope of Work

2.1
Mr. David Meinie of PetroSA presented a summary of the scope of work and provided background information on the tanks scheduled for demolition.

The following points were discussed and clarified:

- The tanks are redundant and no longer in service.

Directors:
Ms Brenda Moagi; Mr Llewellyn Delport; Mr Tembinkosi Bonakele; Ms Ditsietsi Morabe
Group Chief Executive Officer (acting): Ms Sesakho Magadla
Group Chief Financial Officer: Ms Nombulelo Tyandela
Group Company Secretary: Ms Marlene Khumalo

- Tenderers confirmed that the scope of work was generally clear.
- One tank was observed to be in a severely deteriorated condition and was considered structurally unstable.
- It was noted that additional safety precautions and controls will be required during the demolition of this tank.
- The successful tenderer will be required to arrange and fund medical examinations for all personnel involved in the project. Medicals must be aligned to PetroSA requirements, particularly where private medical providers are utilised. An allowance of 1 week must be made for the medicals, badging and Permit to work training.
- Work will be performed during normal day-shift hours unless otherwise approved by PetroSA.
- Tenderers will be required to provide all equipment necessary for the execution of the demolition works, irrespective of the size or nature of the equipment.
- In response to a question regarding project duration, PetroSA confirmed that no predetermined project timeline has been established. Tenderers are therefore required to submit a proposed execution schedule as part of their tender submission.
- Tenderers were informed that the Safety Authorization, which includes a risk assessment, approval process typically takes approximately one week.
- Site working hours are from 07:00 to 17:00. These hours exclude toolbox talks and any other pre-work safety activities that may be required.
- PetroSA will provide a dedicated safety standby person for the project in accordance with Permit-to-Work requirements. This resource does not replace the contractor's appointed safety officer and is an additional PetroSA safety requirement.
- The importance of maintaining strict safety standards throughout the project was emphasized.
- The anticipated commencement date for the project is April 2027, by which time the tender process is expected to have been completed.
- PetroSA's standard payment terms of 30 days from the date of invoice were confirmed.
- Tenderers were advised to include a proposed payment structure in their tender submissions. The final payment structure will be negotiated and agreed upon with the successful tenderer during contract finalization.

- The tender validity period was confirmed as 180 days from the tender closing date.

---

3. Closure
3.1
There being no further business to discuss, the meeting was adjourned at 10h36.
