



Technical Evaluation Criteria
Supplying and Delivery of Breaker Test instrument (Dilo SF6 GAS ANALYSER)

Tender

		Evaluation Criteria for breaker test instrument (Dilo SF6 GAS ANALYSER)	
Number	Criteria Description	Evidence	Weighting
1	1.1 Operating voltage 85-264V AC 1.2 measuring time of 10 min Variables calculated by the system depending on the gas quality 1.3 Measring sensor range 0-100 vol-%sf6	Supply to confirm by submitting the correct specification document for SF6 Gas analyser	70%
2	Previous experience	Submit proof inform of letter or an order delivering similar product to any client. Submission on 3 orders will score 20% and less than 3 orders will score 10% and no submission will score 0%	20%
3	Product Picture	Submit a picture of the SF6 Dilo Gas	10%
Threshold			90%
Total			100%

Name	Mduduzi Mkhabela	
Designation	Supervisor	
Signature		Date: 31 July 2025