

Note:

Reference to the document below and the point 3.3 in question, the following:

240-185000041 Rev 01

Specification for new SF6 gas supplied in standard gas cylinders for NTCSA.

3.3. Cylinder – Type, colour and marking

SF6 shall be supplied in Class 1 seamless metallic cylinders (Class 3 will also be accepted under the prescribed specifications).

Each bottle shall be supplied with a removeable enclosed top valve cover.

There is no preference to colour of the cylinder, but the wording “Sulphur Hexafluoride” is to be painted onto the bottle in vertical format with a black letter size of at least 75mm for the 50-litre bottle. (The letter sizes for the 20 and 10 litre bottles must be in relation to that of the 50-litre bottle.)

The name of the **OEM** is to be added to the bottle in painted or stamped format but not by paste on sticker format.

Cylinder stampings shall comply with the requirements of an approved manufacturing standard according to the requirements of SANS 10019.

As confirmed in the initial clarification meeting and again confirmed in the meeting of 12 May 2025, the following change is to be made on point 3.3 for this document regarding this 5 Year NTCSA National SF6 tender

The name of the **Supplier** is to be added to the bottle in painted or stamped format but not by paste on sticker format.

Supported:



Frik Schoeman ECSA
Senior Consultant (GIS)
NTCSA