

No.	Reference	Date Received	Clarification Required	TNPA Response Date	TNPA Response				
1	Commercial	8-Sep-26	Kindly assist by sending us the electronic BOQ (Excel) for pricing purposes only & drawing / specifications for the Earthing in the Electrical BOQ - TPD-004- EARTHINGSPEC	11-Sep-26	BOQ (Excel) will be issued with the minutes. Addendum 003 will be issued with TPD-004- EARTHINGSPEC, there are no drawings that form part of the earthing spec.				
2	Technical	10-Sep-26	Clarity on the Phase 1 Dates – Document shows Access only 5 February 2027 but completion 9 December 2026	11-Sep-26	Phase 1 (22 February 2027 to 23 June 2027) Phase 2 (24 June 2027 to 14 October 2027) Phase 3 (18 October 2027 to 08 December 2027) Addendum 003 will be issued.				
End of Rev 00									
3	Commercial	11-Sep-26	On Addendum no.002 it was mentioned that “7. C2.2 Bill of Quantities, Final Summary, replace page 3 & 85 of 85 of C2.2 Bill of Quantities with attached page 3 & 85 of 85 of C2.2 Bill of Quantities” but it’s not attached. Kindly furnish us with replacement pages 3 & 85.	11-Sep-26	Page 3 & 85 of 85 of C2.2 Bill of Quantities, revised Addendum 002 will be issued.				
End of Rev 01									
4	Technical	17-Sep-26	With reference to the Mechanical BOQ (HVAC), kindly confirm which drawing refers to the following please: <table><tr><td>2.98</td><td>Extraction Fan as shown on the drawings</td><td>No</td><td>1</td></tr></table>	2.98	Extraction Fan as shown on the drawings	No	1	17-Sep-26	The ventilation unit is shown in the second-floor HVAC drawing, kitchenette near the Queen Elizabeth Boardroom, with an operational capacity of 38 L/s. The corresponding drawing number is XDNE037-1-100-M-LA-0003-0-0A.
2.98	Extraction Fan as shown on the drawings	No	1						
End of Rev 02									
5	Technical	21-Sep-26	T2.2-03 Evaluation Schedule – Company Previous Experience - Page 2 of 8 Please confirm for sub-contractor’s past experience in HVAC and electrical works can you list down your company if you have experience instead of listing down sub-contractors?	22-Sep-26	Yes, you may list your company’s relevant HVAC and Electrical Works experience. You are not required to engage a subcontractor if your company has the necessary expertise, resources, and proven experience to undertake these works. In such cases, your company’s past experience may be submitted in support of the tender requirements.				
6	Addendum	22-Sep-26	Please advise on whether there are any addendums for this tender, if so please send me a copy.	22-Sep-26	All addendums and clarifications has been uploaded on the Transnet eTender Portal as well as the National Treasury eTender portal.				
End of Rev 03									
7	Returnable	22-Sep-26	Please also advise whether the returnable documents are required to be submitted within the specific schedule provided in the tender document, or whether they may be attached separately as annexures to the tender submission, provided that all required returnables are included.	23-Sep-26	It is preferred that the supporting documents be attached directly behind the relevant schedule to which they relate. This assists the evaluation team in verifying compliance and locating the required information efficiently. However, should the documents be submitted as annexures, they should be clearly referenced and cross-referenced to the applicable schedule.				
End of Rev 04									