

Technical Evaluation Criteria Supply of BLU-A Series Battery Load Unit for NTCSA Northern Grid

CLAUSE	DESCRIPTION	WEIGHT (%)	COMMENT(S)
1	APPLICABLE	40%	
1.1	voltage: 5,25V - 300V DC battery voltages		
2	DISCHARGE POWER	25%	
2.1	Up to 19,7kW		
3	WEIGHT	10%	
3.1	14.5 kg		
4	DISCHARGE CURRENT	25%	
4.1	Up to 240A		
	Total	100%	
	Threshold	100%	

Returnable to be: Photos of items need to be supplied or a write up of the product with its technical specification.

	Compiled By	Reviewed By	Supported By
Name & Surname	Nicholas Baloyi	Ellan Phaahla	Ellan Phaahla
Designation	Snr Supervisor	Middle Manager	Middle Manager
Unique No	4191120	1291274	1291274
Signature			