



CITY OF CAPE TOWN
ISIXEKO SASEKAPA
STAD KAAPSTAD

**FINANCE
SUPPLY CHAIN MANAGEMENT**

Sinethemba Ernest Mpata
SCM Practitioner

T: 021 444 0398

E: SCM.Energy@capetown.gov.za

NOTICE TO TENDERERS NO: 1

11 September 2024

TENDER NUMBER: 055G/2024/25

**DESCRIPTION: MANUFACTURE, TESTING, SUPPLY, WAREHOUSING, CUTTING AND DELIVERY OF
MEDIUM VOLTAGE UNDERGROUND CABLE**

CLOSING DATE OF TENDER: 03 October 2024

BOX NUMBER: 118

CLARIFICATION MEETING

The following Addendum is issued in terms of this Tender. This Notice to Tenderers forms an integral part of the Contract.

Tenderers should take note of the following:

Minutes, questions and answers of the briefing session held on 10 September 2024 are attached.
Presentation of the briefing session held on 10 September 2024 are attached.

Tenderers are to return a signed copy of this notice/addendum with the submission of their Tender.
Failure to return a signed copy of the Addendum may result in the Tender being declared Non-Responsive.

Yours faithfully,
Sinethemba
Mpata

Digitally signed by Sinethemba
Mpata
Date: 2024.09.11 14:03:33 +02'00'

For:

Director: Supply Chain Management

Acknowledgement of Receipt of Notice 1 for and on Behalf of the Tenderer

TENDERER:

SIGNED ON BEHALF OF TENDERER:

DATE:.....

TENDER 055G/2024/25: MANUFACTURE, TESTING, SUPPLY, WAREHOUSING, CUTTING AND DELIVERY OF MEDIUM VOLTAGE UNDERGROUND CABLE

TENDER CLARIFICATION MEETING

Date: 10 September 2024

Time: 10:00

Venue: Skype Meeting

1. DISCUSSION POINTS

- 1.1 The clarification meeting is a non-compulsory meeting. Furthermore, it is an opportunity to emphasize certain key aspects of the tender and clarify areas of uncertainty. It is not a comprehensive discussion of the tender document.
- 1.2 Introduction
- 1.3 Tenderer Requirements
- 1.4 Conditions and tenderers Obligations
- 1.5 Tender Responsiveness Criteria
- 1.6 Conditions of Tender (General Comments)
 - 1. 6.1 Preference Schedule
 - 1. 6.2 Attachments
 - 1. 6.3 Tender pricing
 - 1. 6.4 Independent Bid Determination
 - 1. 6.5 Quantities
- 1.7 Technical Specification
- 1.8 Particulars and Returnables
- 1.9 Contract Award
- 1.10 Delivery Period
- 1.11 Contract Price Adjustment (CPA) **Base Month September 2024.**
- 1.12 Local Content (Not Applicable)
- 1.13 Amendments to Tender
- 1.14 Clarification by Tenderer

2 QUESTIONS & ANSWERS

- 2.1 Question 1 – Sample of a “material deviation”.

Answer: Item not complying to the specification i.e. 16mm² Cu cable specified and 15mm² offered.

Meeting adjourned.