

 Eskom	Tender Questions and Answers	Document Identifier	240-7124948	Rev	1
		Effective Date	01 April 2023		
		Review Date	April 2026		

To whom it may concern	Date	08 October 2026
	Enquiries	Yvonne Hadden
	E-mail address	HaddenY@eskom.co.za

Dear Sir/Madam

Request for Enquiry Number	E3480DXKZNOU
Description / Project Title	For the Provision of Supervision, Labour, Equipment, Material (except for the Eskom Free Issue material, i.e Wooden Poles, Concentric Cable, Meters and Pole Top Split Meter Boxes) for the Electrification of 60 Off-Grid Connections at Maqhashiya Village using Solar PV and a further 12-month post installation maintenance in the KZN Operating Unit, Central East Cluster
Tender Questions Closing Date	08 October 2026

Item	Questions	Answers	Clarity Published Dates
1.	BOQ – ready boards are being supplied by Eskom but there is no provision in the BOQ for the installation	A line item for the installation of Eskom supplied ready boards have been added to the BOQ as line item 3.35 of the updated BOQ. PLEASE CHECK ADDENDUM FOLDER FOR ADDENDUM 4 AND REVISED BOQ	07 October 2026

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

 Eskom	Tender Questions and Answers	Document Identifier	240-7124948	Rev	1
		Effective Date	01 April 2023		
		Review Date	April 2026		

Item	Questions	Answers	Clarity Published Dates
2.	BOQ – Has provision been made for the service connection pole, pigtail and strain clamp	Yes, provision was accounted for in line item 3.30 of the SHS Bill for the supply of accessories required for all service connection pole, tenderers are to ensure that the tendered rate for item 3.30 includes the supply of the necessary accessories/hardware.	07 October 2026
3.	Page 20 of 42 states 4x4 minimum qty 1 (indicates 5% per vehicle) total 10%, however vehicle register only has space for 1 4x4. How many 4x4 vehicles do you require 1 or 2 ??	A minimum of one 4x4 bakkie is required and shall be captured in the first row of the vehicle register carrying a rating of 5%. A second 4x4 bakkie also rated at 5% can be captured under “Other Vehicle” row in the vehicle register. Ensure that Column E is completed to indicate the vehicle type either 4x4 single cab or 4x4 double cab.	07 October 2026

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30