

ETHEKWINI MUNICIPALITY

ENGINEERING SERVICES DIRECTORATE: DEVELOPMENT ENGINEERING DIVISION

CONTRACT NO. 3V - 31855

CITY HALL PRECINCT UPGRADE, WARD 28

NOTICE NUMBER 1 TO TENDERERS: 15 OCTOBER 2025

1. This addendum is issued in terms of Clause C.2.6 of the Standard Conditions of Tender. The Tenderers are instructed to make the alterations as listed in this addendum, to the tender documentation.
2. Page 5 of the Tender document, T.1.1.3: Notes to Tenderers, eThekwin SCM Policy: Please change item no. 1 from: **Section 14(4): ETM Supplier Database** to : **Section 14(5): ETM Supplier Database**.
3. Page 22 of the Tender document, C.2: Tenderers Obligations, C2.2.20 Submit securities, bonds, policies: Please delete the entire paragraph, **"The Tenderer is required to submit with their tender offer a letter of intent from an approved insurer undertaking to provide the Performance Bond to the format included in T2.2 of this procurement document"**.
4. Page 7 of the Bill Of Quantities (BOQ) of the Tender document, Section 3, Part EC, Item 1 : Delete , **"Cement Treated graded crush stone 150 mm thick"** and replace with, **"300 mm thick C3 cement treated subbase, (2 x 150 mm lifts)"**.
5. Page 8 of the Bill Of Quantities (BOQ) of the Tender document, Section 3, Part EG, Items 2,3,4,5 and 6: please note the amended standard specification payment clause on page 152 and 153, **PS.EG.8.2, "The unit of measurement shall be square metres (m²) of paved area and metre (m) of header course. The tendered rate shall include for supplying the clay brick paving and sand, placing the bedding layer, laying the bricks, cutting the bricks to fit edge restraints, compacting the pavement, filling gaps as specified, filling joints and removing excess sand and the supply and application of weed killer. The rate shall also include for all saw cutting (Intricate or normal)". BOQ to be read in conjunction with the tender drawings, Drawing No. 49434.**

RETURN OF THIS NOTICE NO. 1

- 6.1 This notice forms part of the contract and is to be signed, dated and returned together with the tender documents.
- 6.2 As proof of receipt of this Notice No.1 to Tenderers, please sign and e-mail back to this Department-page 2 of this notice.

A handwritten signature in black ink, appearing to be 'M. Key', is written over a horizontal line.

DD: DEVELOPMENT ENGINEERING

ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM

I, (name) acknowledge receipt of

Addendum #1 for Contract No. 3V 31855: CITY HALL PRECINCT UPGRADE WARD 28,
DATED 15 / 10 / 2025

NAME OF FIRM: _____

SIGNATURE: _____

SIGNED AT: _____

DATE: _____

**This page must be completed and e-mailed back to mabandla.adoons@durban.gov.za
or vuyo.adoons@durban.gov.za.**