

ERRATUM

DEPARTMENT/ INSITUION	PTB NO	BID NUMBER & PROJECT DESCRIPTION	CONTACT PERSON										
DEPT OF AGRICULTURE	09	SCMU8-26/27-0033 Bid for the supply, delivery, installation, testing & commissioning of a 300kva, three phase diesel backup generator at Seven Stars Dairy in Amahlathi Municipality of the Amathole District <u>REASONS FOR ERRATUM</u> Page 142 should read: <u>ENGINE</u>: Diesel engine capable of producing 300 kVA @ sea level under standby conditions. (Preferred engines: Perkins/CAT/Volvo/John Deere or other Brands approved by the Engineer with a service centre within South Africa. Page 98 should read: <table><tr><td>B.1.3</td><td>PPS3</td><td>Up to 300mm² x 4c with 16mm BCE</td><td>m</td><td>50.0</td></tr><tr><td>B.1.4</td><td></td><td>Allow for extra cables and terminations and</td><td></td><td></td></tr></table>	B.1.3	PPS3	Up to 300mm ² x 4c with 16mm BCE	m	50.0	B.1.4		Allow for extra cables and terminations and			SCM SPECIFIC ENQUIRIES Ms D McGregor 043 7068771 Debra.mcgregor@ecagriculture.gov.za TECHNICAL/PROJECT SPECIFIC Mr B Giyama 043 7068705 Bongani.giyama@ecagriculture.gov.za
B.1.3	PPS3	Up to 300mm ² x 4c with 16mm BCE	m	50.0									
B.1.4		Allow for extra cables and terminations and											