

BID NUMBER: NRF/ILABS IOP1/47/2024-25

BID DESCRIPTION: APPOINTMENT OF A SPECIALIST CONTRACTOR FOR THE DESIGN VERIFICATION, MANUFACTURE/PROCUREMENT, DELIVERY, INSTALLATION, COMMISSIONING, QUALIFICATION AND GUARANTEE OF THE D-BLOCK & N-BLOCK HEAT, VENTILATION AND AIR CONDITIONING (HVAC) SYSTEM TO THE EXISTING RADIOPHARMACEUTICAL PRODUCTION FACILITY AT ITHEMBA LABS, FAURE WESTERN CAPE, SOUTH AFRICA.

The questions received and responses for the bid are as following:

<u>Questions</u>	<u>Responses</u>
1. Filter List	See attached the updated filter list with the corrected filter quantities and capacities highlighted in yellow. Please note: a. HEPA filters are referred to as "bag" filters, but the intention is "box" or "V-Bank"

	b. Galvanised filter frames are acceptable for primary filter banks. c. Plastic frames are acceptable for secondary filter banks.
2. Queries / Clarifications	Please note that as per C3.1 of the tender document, no further clarifications are allowed.
3. Tender Closing Date	Please note that the tender closing date remains 24 January 2025 as per tender document.
4. AHU Discharge Pressure typing error	Tenderers to please note that the discharge pressure units are incorrectly stated as kPa on the AHU datasheets. It should be stated in Pa.