

ADDENDUM

Date: 01 July 2026
Subject: Responses to questions asked at the site inspection held on the 26 & 29 June 2026
RFQ: 74391
RFQ Description: REQUEST FOR BIDS OF THE SUPPLY AND DELIVERY OF GENERATOR REMOTE MONITORING TOOL AT AIRPORTS COMPANY SOUTH AFRICA - OR TAMBO INTERNATIONAL AIRPORT
Date RFQ published: 15 June 2026
Date of site inspection: 26 & 29 June 2026

1. Q: Sim card- are tenderers supplying the sim cards or ACSA will?

A: ACSA will provide the sim card

2. Q: Circuit breaker- Do we need to supply circuit breakers?

A: No, focus only on the gateway, and associated accessories.

3. Q: The BOQ shows 16 units for supply however there is 18 substations eg substation 11(x2)?

A: The BOQ requirement for 16 gateways is correct. Although there are 18 generators, Substation 11 has two generators operating within the same substation, and a single gateway will be utilised for both generators. The communication cable will be provided.

4. Q: Are u aware the recommendation from OEM is R5485 for the 86-range controller not USB cable?

A: Yes, we are aware. The OEM-recommended R5,485 communication cable will be provided by ACSA. Kindly submit your quotation strictly in accordance with the requirements specified in the BOQ.

5. Q: Are the generators in sync (do they communicate each with each other or indiviually)?

A: The generators are distributed across the airport, as indicated in the BOQ, and therefore operate independently at their respective substations. The exception is Substation 11, and others, where the two generators are synchronised and communicate with each other.

6. Q: Do you already have a monitoring account?

A: Yes, an existing monitoring account is already in place.

7. Q: Who does the commissioning and programming

Tel +27 11 723 1400 Fax +27 11 453 9354

Western Precinct, Aviation Park, O.R. Tambo International Airport, 1 Jones Road, Kempton Park, Gauteng, South Africa, 1632
P O Box 75480, Gardenview, Gauteng, South Africa, 2047
www.airports.co.za

A: Commissioning of gateway, etc and programming will be completed on the existing monitoring account.

8. Q: Are you able to provide pictures of the panel inside and outside for all generators considering the fact that there is mobile generator airside that is different from others

A: A photograph of one generator panel as an example is provided below, as the majority of the generator panels are of a similar configuration.



Tel +27 11 723 1400 Fax +27 11 453 9354

Western Precinct, Aviation Park, O.R. Tambo International Airport, 1 Jones Road, Kempton Park, Gauteng, South Africa, 1632
P O Box 75480, Gardenview, Gauteng, South Africa, 2047
www.airports.co.za

Airports Company South Africa SOC Ltd Reg No 1993/004149/30 VAT no 4930138393 Board of Directors: Mr Irvin Phenyane (Chairperson), Dr Kgabo Badimo, Ms Dudu Hlatshwayo, Mr Andile Khumalo, Ms Lwazikazi Nopece, Mr Theunis Chamberlain, Mr Roy Mnisi, Mr Surendra Sooklal, Ms Xoliswa Daku, Ms Keitumetse Mahlangu, Ms Mpumi Mpofu (Chief Executive Officer), Mr Luzuko Mbotya (Chief Financial Officer), Ms Fefekazi Sefara (Company Secretary)

Name	Designation	Signature	Date
SCM	Buyer		1 July 2026
Member 1	Technical		1 July 2026
Member 2			

Tel +27 11 723 1400 Fax +27 11 453 9354

Western Precinct, Aviation Park, O.R. Tambo International Airport, 1 Jones Road, Kempton Park, Gauteng, South Africa, 1632
P O Box 75480, Gardenview, Gauteng, South Africa, 2047
www.airports.co.za

Airports Company South Africa SOC Ltd Reg No 1993/004149/30 VAT no 4930138393 Board of Directors: Mr Irvin Phenyane (Chairperson), Dr Kgabo Badimo, Ms Dudu Hlatshwayo, Mr Andile Khumalo, Ms Lwazikazi Nopece, Mr Theunis Chamberlain, Mr Roy Mnisi, Mr Surendra Sooklal, Ms Xoliswa Daku, Ms Keitumetse Mahlangu, Ms Mpumi Mpofu (Chief Executive Officer), Mr Luzuko Mbotya (Chief Financial Officer), Ms Fefekazi Sefara (Company Secretary)