


SYSTEM VOLTAGE 400V 3 PHASE+N
BUSBAR RATING 500A
FAULT LEVEL 20kA
COLOUR : ELECTRIC ORANGE TO SANS 1091-1975 SHADE B26
LENGTH : 1200mm
HEIGHT : 2200mm
DEPTH : 800mm
MATERIAL 2mm MS PLATE
BOTTOM CABLE ENTRY
FRONT AND BACK ACCESS
IP44

CLIENT: TRANSNET national ports authority

Client Name:

Designation & Section: ELECTRICAL ENGINEER: PORT ENGINEERING

Client Signature: Project Phase 0

Date:

Contact No.'s:

No.	DATE	REVISION DETAIL
00	11-12-2020	ORIGINAL
01	27-11-2022	APPROVED FOR CONSTRUCTION (AFC)

Main Contractor:
Stateway Switchboards (Pty) Ltd.
55 Second Road, Linbro Park, Sandton. P.O. Box 1055, Linbro Park 2065. TEL. +27(0) 11 021 7260 FAX. +27(0) 86 503 2258

Main Contractor: STATEWAY SWITCHBOARDS (PTY.) LTD.

ZML Africa Drawing No.: TNPA/2020

Consultant:
Z.M.L Africa Group
Engineering Africa Forward

Site Address:
Sturrock Dry Dock, Cape Town

Building Name:
Combined Pumphouse and Graving Dock Substation

Project Description:
Sturrock Dry Dock Electrical Infrastructure Upgrades: Graving Dock Substation - Sketch Plan

Drawing Description:
Berrio Road Kiosk LV Board - General Arrangement Layout

Drawn:	P.MAZIBUKO	Date:	29 / 07 / 2021
Designer / Checked:	M.SHEZI	Scale:	AS SHOWN
Approved:	M.SHEZI	Drawing Size:	A3
Prof Reg. No.	20110108	Revision No:	01
Signature:			27/11/2022

Drawing Numbers: TNPA/2020-000-E-BKB-0001

Site & Building No.	Floor No.	Discipline & Service Type

Sheet Number	Project Number	Proposal No
002		000