



SPEC SHEET

SAP MATERIAL No.:	0402167							
SHORT DESCRIPTION:	CT+VT 11kV-110V B 3VT+3CT I/LD D3118							
TECH. DESCRIPTION: CT + VT METERING UNIT * 11kV * 110V * 25VA * TYPE B * OIL FILLED * POLE MOUNTED * SUPPLIED WITH : 3 x VT WITH RATIO 11000-110V 25VA PER PHASE CLASS 0.2, 3 x CT 200/1A SINGLE-RATIO CLASS 0.2 S BURDEN 5VA STC 20kA FOR 1 SECOND, 6 x 11kV OUTDOOR BUSHINGS * USED FOR INLAND APPLICATIONS * ESKOM DRAWING No. D-DT-3118 *								
SAP MATERIAL No.:	0175934							
SHORT DESCRIPTION:	CT+VT 11kV-110V B 3VT+3CT CSTL D3118							
TECH. DESCRIPTION: CT + VT METERING UNIT * 11kV * 110V * 25VA * TYPE B * OIL FILLED * POLE MOUNTED * SUPPLIED WITH : 3 x VT WITH RATIO 11000-110V 25VA PER PHASE CLASS 0.2, 3 x CT 200/1A SINGLE-RATIO CLASS 0.2 000S BURDEN 5VA STC 20kA FOR 1 SECOND, 6 x 11kV OUTDOOR BUSHINGS * USED FOR COASTAL APPLICATIONS * ESKOM DRAWING No. D-DT-3118 *								
ITEM	:- CT + VT 2 + 3 PHASE TYPE B + C							
MATERIAL SPECIFICATION	:-							
CORROSION SPECIFICATION	:- DSP 34_1658							
STANDARD SPECIFICATION	:-							
ESKOM SPECIFICATION	:- DSP 34-870							
TEST & CERTIFICATION REQUIREMENTS :- SANS 60044-3								
INSPECTION	Yes	No	ESKOM RELEASE NOTE			Yes	No	
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS								
11	VARIOUS SAP NUMBERS CHANGED AND VA'S AN CT'S ON ALL REMAINING UNITS CHANGED AND SAP'S 0008726-27, 0175932-33, 0180232-33, 0219348-53 REMOVED		P.A.T.	M.SHUTER	B.MWAREHWA	02.10.2012		
10	0180235 – CT RATIO CORRECTED		P.A.T.	B. MWAREHWA	V. SINGH	03.12.2010		
9	SHORT DESCRIPTIONS CORRECTED, SAP 0175938 – 0175941 REMOVED AND CORROSION + ESKOM SPEC CHANGED		N.M. P.A.T.	B. MWAREHWA	B. MWAREHWA	18.05.2009		
REV	REVISION DESCRIPTION		BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	P. CROWDY	DATE:	16.03.1998	 D-DT-3118		SAP No:		
CHKD:	D. PILLAY	DATE:	16.03.1998			0402167		
DRAWN:	P.A. VERMAAK	DATE:	26.01.1998			0175934		
						SET	SHEET	REV
						10	1	11


SPEC SHEET

SAP MATERIAL No.:		0402169							
SHORT DESCRIPTION:		CT+VT 22kV-110V B 3VT+3CT I/LD D3118							
TECH. DESCRIPTION:									
CT + VT METERING UNIT * 22kV * 110V * 25VA *									
TYPE B * OIL FILLED * POLE MOUNTED *									
SUPPLIED WITH :									
3 x VT WITH RATIO 22000-110V 25VA PER PHASE CLASS 0.2,									
3 x CT 200/1A SINGLE-RATIO CLASS 0.2 S									
BURDEN 5VA STC 20kA FOR 1 SECOND,									
6 x 22kV OUTDOOR BUSHINGS *									
USED FOR INLAND APPLICATIONS *									
ESKOM DRAWING No. D-DT-3118 *									
SAP MATERIAL No.:		0175935							
SHORT DESCRIPTION:		CT+VT 22kV-110V B 3VT+3CT CSTL D3118							
TECH. DESCRIPTION:									
CT + VT METERING UNIT * 22kV * 110V * 25VA *									
TYPE B * OIL FILLED * POLE MOUNTED *									
SUPPLIED WITH :									
3 x VT WITH RATIO 22000-110V 25VA PER PHASE CLASS 0.2,									
3 x CT 200/1A SINGLE-RATIO CLASS 0.2 S									
BURDEN 5VA STC 20kA FOR 1 SECOND,									
6 x 22kV OUTDOOR BUSHINGS *									
USED FOR COASTAL APPLICATIONS *									
ESKOM DRAWING No. D-DT-3118 *									
11	VARIOUS SAP NUMBERS CHANGED AND VA'S AN CT'S ON ALL REMAINING UNITS CHANGED AND SAP'S 0008726-27, 0175932-33,0180232-33, 0219348-53 REMOVED			P.A.T.	M.SHUTER	B.MWAREHWA	02.10.2012		
10	0180235 – CT RATIO CORRECTED			P.A.T.	B. MWAREHWA	V. SINGH	03.12.2010		
9	SHORT DESCRIPTIONS CORRECTED, SAP 0175938 – 0175941 REMOVED AND CORROSION + ESKOM SPEC CHANGED			N.M. P.A.T.	B. MWAREHWA	B. MWAREHWA	18.05.2009		
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	P. CROWDY	DATE:	16.03.1998	SCALE NTS			SAP No:		
CHKD:	D. PILLAY	DATE:	16.03.1998	CAD REF:			0402169		
				SERIES 3000			0175935		
DRAWN:	P.A. VERMAAK	DATE:	26.01.1998	FILE No:	D-DT-3118		SET	SHEET	REV
				3118			10	2	11

SPEC SHEET

SAP MATERIAL No.:		0180234						
SHORT DESCRIPTION:		CT+VT 33kV-110V B 3VT+3CT I/LD D3118						
TECH. DESCRIPTION:								
CT + VT METERING UNIT * 33kV * 110V * 25VA *								
TYPE B * OIL FILLED * POLE MOUNTED *								
SUPPLIED WITH :								
3 x VT WITH RATIO 33000-110V 25VA PER PHASE CLASS 0.2,								
3 x CT 200/1A SINGLE-RATIO CLASS 0.2 S								
BURDEN 5VA STC 20kA FOR 1 SECOND,								
6 x 33kV OUTDOOR BUSHINGS *								
USED FOR INLAND APPLICATIONS *								
ESKOM DRAWING No. D-DT-3118 *								
SAP MATERIAL No.:		0180235						
SHORT DESCRIPTION:		CT+VT 33kV-110V B 3VT+3CT CSTL D3118						
TECH. DESCRIPTION:								
CT + VT METERING UNIT * 33kV * 110V * 25VA *								
TYPE B * OIL FILLED * POLE MOUNTED *								
SUPPLIED WITH :								
3 x VT WITH RATIO 33000-110V 25VA PER PHASE CLASS 0.2,								
3 x CT 200/1A SINGLE-RATIO CLASS 0.2 S								
BURDEN 5VA STC 20kA FOR 1 SECOND,								
6 x 33kV OUTDOOR BUSHINGS *								
USED FOR COASTAL APPLICATIONS *								
ESKOM DRAWING No. D-DT-3118 *								
11	VARIOUS SAP NUMBERS CHANGED AND VA'S AN CT'S ON ALL REMAINING UNITS CHANGED AND SAP'S 0008726-27, 0175932-33,0180232-33, 0219348-53 REMOVED		P.A.T.	M.SHUTER	B.MWAREHWA	02.10.2012		
10	0180235 – CT RATIO CORRECTED		P.A.T.	B. MWAREHWA	V. SINGH	03.12.2010		
9	SHORT DESCRIPTIONS CORRECTED, SAP 0175938 – 0175941 REMOVED AND CORROSION + ESKOM SPEC CHANGED		N.M. P.A.T.	B. MWAREHWA	B. MWAREHWA	18.05.2009		
REV	REVISION DESCRIPTION		BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	P. CROWDY	DATE:	16.03.1998			SAP No:		
CHKD:	D. PILLAY	DATE:	16.03.1998			0180234		
DRAWN:	P.A. VERMAAK	DATE:	26.01.1998			0180235		
				D-DT-3118		SET	SHEET	REV
						10	3	11

SPEC SHEET


SAP MATERIAL No.:		0175936							
SHORT DESCRIPTION:		CT+VT 19.5kV-63.5V B 1VT+1CT I/LD D3118							
TECH. DESCRIPTION:									
CT + VT METERING UNIT * 19.5kV * 63.5V * 25VA *									
TYPE B * OIL FILLED * POLE MOUNTED *									
SUPPLIED WITH :									
1 x VT WITH RATIO 19500-63.5V 25VA PER PHASE CLASS 0.2,									
1 x CT 200/1A SINGLE-RATIO CLASS 0.2 S									
BURDEN 5VA STC 20kA FOR 1 SECOND,									
2 x 33kV OUTDOOR BUSHINGS *									
USED FOR INLAND APPLICATIONS *									
ESKOM DRAWING No. D-DT-3118 *									
SAP MATERIAL No.:		0175937							
SHORT DESCRIPTION:		CT+VT 19.5kV-63.5V B 1VT+1CT CSTL D3118							
TECH. DESCRIPTION:									
CT + VT METERING UNIT * 19.5kV * 63.5V * 25VA *									
TYPE B * OIL FILLED * POLE MOUNTED *									
SUPPLIED WITH :									
1 x VT WITH RATIO 19500-63.5V 25VA PER PHASE CLASS 0.2,									
1 x CT 200/1A SINGLE-RATIO CLASS 0.2 S									
BURDEN 5VA STC 20kA FOR 1 SECOND,									
2 x 33kV OUTDOOR BUSHINGS *									
USED FOR COASTAL APPLICATIONS *									
ESKOM DRAWING No. D-DT-3118 *									
11	VARIOUS SAP NUMBERS CHANGED AND VA'S AN CT'S ON ALL REMAINING UNITS CHANGED AND SAP'S 0008726-27, 0175932-33,0180232-33, 0219348-53 REMOVED			P.A.T.	M.SHUTER	B.MWAREHWA	02.10.2012		
10	0180235 – CT RATIO CORRECTED			P.A.T.	B. MWAREHWA	V. SINGH	03.12.2010		
9	SHORT DESCRIPTIONS CORRECTED, SAP 0175938 – 0175941 REMOVED AND CORROSION + ESKOM SPEC CHANGED			N.M. P.A.T.	B. MWAREHWA	B. MWAREHWA	18.05.2009		
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	P. CROWDY	DATE:	16.03.1998	SCALE NTS	 D-DT-3118		SAP No:		
CHKD:	D. PILLAY	DATE:	16.03.1998	CAD REF:			0175936		
				SERIES 3000			0175937		
DRAWN:	P.A. VERMAAK	DATE:	26.01.1998	FILE No:			SET	SHEET	REV
				3118			10	4	11

SPEC SHEET


SAP MATERIAL No.:		0175942					
SHORT DESCRIPTION:		CT+VT 11kV-110V B 3VT+3CT CBL I/LD D3118					
TECH. DESCRIPTION:							
CT + VT METERING UNIT * 11kV * 110V * 25VA *							
TYPE B * OIL FILLED * GROUND MOUNTED *							
SUPPLIED WITH :							
3 x VT WITH RATIO 11000-110V 25VA PER PHASE CLASS 0.2,							
3 x CT 200/1A SINGLE-RATIO CLASS 0.2 S							
BURDEN 5VA STC 20kA FOR 1 SECOND,							
2 x AIR-INSULATED CABLE TERMINATION ENCLOSURES *							
USED FOR INLAND APPLICATIONS *							
ESKOM DRAWING No. D-DT-3118 * C *							
SAP MATERIAL No.:		0175943					
SHORT DESCRIPTION:		CT+VT 11kV-110V B 3VT+3CT CBL CSTL D3118					
TECH. DESCRIPTION:							
CT + VT METERING UNIT * 11kV * 110V * 25VA *							
TYPE B * OIL FILLED * GROUND MOUNTED *							
SUPPLIED WITH :							
3 x VT WITH RATIO 11000-110V 25VA PER PHASE CLASS 0.2,							
3 x CT 200/1A SINGLE-RATIO CLASS 0.2 S							
BURDEN 5VA STC 20kA FOR 1 SECOND,							
2 x AIR-INSULATED CABLE TERMINATION ENCLOSURES *							
USED FOR COASTAL APPLICATIONS *							
ESKOM DRAWING No. D-DT-3118 * C *							

SPEC SHEET


SAP MATERIAL No.:		0175967					
SHORT DESCRIPTION:		CT+VT 22kV-110V B 3VT+3CT CBL I/LD D3118					
TECH. DESCRIPTION:							
CT + VT METERING UNIT * 22kV * 110V * 25VA *							
TYPE B * OIL FILLED * GROUND MOUNTED *							
SUPPLIED WITH :							
3 x VT WITH RATIO 22000-110V 25VA PER PHASE CLASS 0.2,							
3 x CT 200/1A SINGLE-RATIO CLASS 0.2 S							
BURDEN 5VA STC 20kA FOR 1 SECOND,							
2 x AIR-INSULATED CABLE TERMINATION ENCLOSURES *							
USED FOR INLAND APPLICATIONS *							
ESKOM DRAWING No. D-DT-3118 * C *							
SAP MATERIAL No.:		0175968					
SHORT DESCRIPTION:		CT+VT 22kV-110V B 3VT+3CT CBL CSTL D3118					
TECH. DESCRIPTION:							
CT + VT METERING UNIT * 22kV * 110V * 25VA *							
TYPE B * OIL FILLED * GROUND MOUNTED *							
SUPPLIED WITH :							
3 x VT WITH RATIO 22000-110V 25VA PER PHASE CLASS 0.2,							
3 x CT 200/1A SINGLE-RATIO CLASS 0.2 S							
BURDEN 5VA STC 20kA FOR 1 SECOND,							
2 x AIR-INSULATED CABLE TERMINATION ENCLOSURES *							
USED FOR COASTAL APPLICATIONS *							
ESKOM DRAWING No. D-DT-3118 * C *							

11	VARIOUS SAP NUMBERS CHANGED AND VA'S AN CT'S ON ALL REMAINING UNITS CHANGED AND SAP'S 0008726-27, 0175932-33,0180232-33, 0219348-53 REMOVED		P.A.T.	M.SHUTER	B.MWAREHWA	02.10.2012		
10	0180235 – CT RATIO CORRECTED		P.A.T.	B. MWAREHWA	V. SINGH	03.12.2010		
9	SHORT DESCRIPTIONS CORRECTED, SAP 0175938 – 0175941 REMOVED AND CORROSION + ESKOM SPEC CHANGED		N.M. P.A.T.	B. MWAREHWA	B. MWAREHWA	18.05.2009		
REV	REVISION DESCRIPTION		BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	P. CROWDY	DATE:	16.03.1998	 Eskom		SAP No:		
CHKD:	D. PILLAY	DATE:	16.03.1998			0175967		
DRAWN:	P.A. VERMAAK	DATE:	26.01.1998			0175968		
				SET	SHEET	REV		
				D-DT-3118		10	6	11

SPEC SHEET


SAP MATERIAL No.:		0216388							
SHORT DESCRIPTION:		CT+VT 11kV-110V C 3VT+3CT CBL I/LD D3118							
TECH. DESCRIPTION:									
CT + VT METERING UNIT * 11kV * 110V * 25VA * TYPE C * OIL FILLED * GROUND MOUNTED * SUPPLIED WITH : 3 x VT WITH RATIO 11000-110V 25VA PER PHASE CLASS 0.2, 3 x CT 400/1A SINGLE-RATIO CLASS 0.2 S BURDEN 5VA STC 20kA FOR 1 SECOND, 2 x AIR-INSULATED CABLE TERMINATION ENCLOSURES * USED FOR INLAND APPLICATIONS * ESKOM DRAWING No. D-DT-3118 * C *									
SAP MATERIAL No.:		0216389							
SHORT DESCRIPTION:		CT+VT 11kV-110V C 3VT+3CT CBL CSTL D3118							
TECH. DESCRIPTION:									
CT + VT METERING UNIT * 11kV * 110V * 25VA * TYPE C * OIL FILLED * GROUND MOUNTED * SUPPLIED WITH : 3 x VT WITH RATIO 11000-110V 25VA PER PHASE CLASS 0.2, 3 x CT 400/1A SINGLE-RATIO CLASS 0.2 S BURDEN 5VA STC 20kA FOR 1 SECOND, 2 x AIR-INSULATED CABLE TERMINATION ENCLOSURES * USED FOR COASTAL APPLICATIONS * ESKOM DRAWING No. D-DT-3118 * C *									
11	VARIOUS SAP NUMBERS CHANGED AND VA'S AN CT'S ON ALL REMAINING UNITS CHANGED AND SAP'S 0008726-27, 0175932-33,0180232-33, 0219348-53 REMOVED			P.A.T.	M.SHUTER	B.MWAREHWA	02.10.2012		
10	0180235 – CT RATIO CORRECTED			P.A.T.	B. MWAREHWA	V. SINGH	03.12.2010		
9	SHORT DESCRIPTIONS CORRECTED, SAP 0175938 – 0175941 REMOVED AND CORROSION + ESKOM SPEC CHANGED			N.M. P.A.T.	B. MWAREHWA	B. MWAREHWA	18.05.2009		
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	P. CROWDY	DATE:	16.03.1998	SCALE NTS	 Eskom		SAP No:		
CHKD:	D. PILLAY	DATE:	16.03.1998	CAD REF:			0216388		
				SERIES 3000			0216389		
DRAWN:	P.A. VERMAAK	DATE:	26.01.1998	FILE No: 3118	D-DT-3118		SET	SHEET	REV
							10	7	11

SPEC SHEET


SAP MATERIAL No.:		0216390						
SHORT DESCRIPTION:		CT+VT 11kV-110V C 3VT+3CT I/LD D3118						
TECH. DESCRIPTION:								
CT + VT METERING UNIT * 11kV * 110V * 25VA * TYPE C * OIL FILLED * POLE MOUNTED * SUPPLIED WITH : 3 x VT WITH RATIO 11000-110V 25VA PER PHASE CLASS 0.2, 3 x CT 400/1A SINGLE-RATIO CLASS 0.2 S BURDEN 5VA STC 20ka FOR 1 SECOND, 6 x 11kV OUTDOOR BUSHINGS * USED FOR INLAND APPLICATIONS * ESKOM DRAWING No. D-DT-3118 *								
SAP MATERIAL No.:		0216391						
SHORT DESCRIPTION:		CT+VT 11kV-110V C 3VT+3CT CSTL D3118						
TECH. DESCRIPTION:								
CT + VT METERING UNIT * 11kV * 110V * 25VA * TYPE C * OIL FILLED * POLE MOUNTED * SUPPLIED WITH : 3 x VT WITH RATIO 11000-110V 25VA PER PHASE CLASS 0.2, 3 x CT 400/1A SINGLE-RATIO CLASS 0.2 S BURDEN 5VA STC 20ka FOR 1 SECOND, 6 x 11kV OUTDOOR BUSHINGS * USED FOR COASTAL APPLICATIONS * ESKOM DRAWING No. D-DT-3118 *								
11	VARIOUS SAP NUMBERS CHANGED AND VA'S AN CT'S ON ALL REMAINING UNITS CHANGED AND SAP'S 0008726-27, 0175932-33,0180232-33, 0219348-53 REMOVED			P.A.T.	M.SHUTER	B.MWAREHWA	02.10.2012	
10	0180235 – CT RATIO CORRECTED			P.A.T.	B. MWAREHWA	V. SINGH	03.12.2010	
9	SHORT DESCRIPTIONS CORRECTED, SAP 0175938 – 0175941 REMOVED AND CORROSION + ESKOM SPEC CHANGED			N.M. P.A.T.	B. MWAREHWA	B. MWAREHWA	18.05.2009	
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS
AUTH:	P. CROWDY	DATE:	16.03.1998	SCALE NTS	 D-DT-3118		SAP No: 0216390	
CHKD:	D. PILLAY	DATE:	16.03.1998	CAD REF: SERIES 3000			0216391	
DRAWN:	P.A. VERMAAK	DATE:	26.01.1998	FILE No: 3118			SET 10	SHEET 8

SPEC SHEET

SAP MATERIAL No.:		0216392					
SHORT DESCRIPTION:		CT+VT 22kV-110V C 3VT+3CT CBL I/LD D3118					
TECH. DESCRIPTION:							
CT + VT METERING UNIT * 22kV * 110V * 25VA *							
TYPE C * OIL FILLED * GROUND MOUNTED *							
SUPPLIED WITH :							
3 x VT WITH RATIO 22000-110V 25VA PER PHASE CLASS 0.2,							
3 x CT 400/1A SINGLE-RATIO CLASS 0.2 S							
BURDEN 5VA STC 20kA FOR 1 SECOND,							
2 x AIR-INSULATED CABLE TERMINATION ENCLOSURES *							
USED FOR INLAND APPLICATIONS *							
ESKOM DRAWING No. D-DT-3118 * C *							
SAP MATERIAL No.:		0216393					
SHORT DESCRIPTION:		CT+VT 22kV-110V C 3VT+3CT CBL CSTL D3118					
TECH. DESCRIPTION:							
CT + VT METERING UNIT * 22kV * 110V * 25VA *							
TYPE C * OIL FILLED * GROUND MOUNTED *							
SUPPLIED WITH :							
3 x VT WITH RATIO 22000-110V 25VA PER PHASE CLASS 0.2,							
3 x CT 400/1A SINGLE-RATIO CLASS 0.2 S							
BURDEN 5VA STC 20kA FOR 1 SECOND,							
2 x AIR-INSULATED CABLE TERMINATION ENCLOSURES *							
USED FOR COASTAL APPLICATIONS *							
ESKOM DRAWING No. D-DT-3118 * C *							

11	VARIOUS SAP NUMBERS CHANGED AND VA'S AN CT'S ON ALL REMAINING UNITS CHANGED AND SAP'S 0008726-27, 0175932-33,0180232-33, 0219348-53 REMOVED		P.A.T.	M.SHUTER	B.MWAREHWA	02.10.2012		
10	0180235 – CT RATIO CORRECTED		P.A.T.	B. MWAREHWA	V. SINGH	03.12.2010		
9	SHORT DESCRIPTIONS CORRECTED, SAP 0175938 – 0175941 REMOVED AND CORROSION + ESKOM SPEC CHANGED		N.M. P.A.T.	B. MWAREHWA	B. MWAREHWA	18.05.2009		
REV	REVISION DESCRIPTION		BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	P. CROWDY	DATE:	16.03.1998	 Eskom		SAP No:		
CHKD:	D. PILLAY	DATE:	16.03.1998			0216392		
DRAWN:	P.A. VERMAAK	DATE:	26.01.1998			0216393		
				D-DT-3118		SET	SHEET	REV
						10	9	11

SPEC SHEET

SAP MATERIAL No.:		0216394							
SHORT DESCRIPTION:		CT+VT 22kV-110V C 3VT+3CT I/LD D3118							
TECH. DESCRIPTION:									
CT + VT METERING UNIT * 22kV * 110V * 25VA *									
TYPE C * OIL FILLED * POLE MOUNTED *									
SUPPLIED WITH :									
3 x VT WITH RATIO 22000-110V 25VA PER PHASE CLASS 0.2,									
3 x CT 400/1A SINGLE-RATIO CLASS 0.2 S									
BURDEN 5VA STC 20kA FOR 1 SECOND,									
6 x 22kV OUTDOOR BUSHINGS *									
USED FOR INLAND APPLICATIONS *									
ESKOM DRAWING No. D-DT-3118 *									
SAP MATERIAL No.:		0216395							
SHORT DESCRIPTION:		CT+VT 22kV-110V C 3VT+3CT CSTL D3118							
TECH. DESCRIPTION:									
CT + VT METERING UNIT * 22kV * 110V * 25VA *									
TYPE C * OIL FILLED * POLE MOUNTED *									
SUPPLIED WITH :									
3 x VT WITH RATIO 22000-110V 25VA PER PHASE CLASS 0.2,									
3 x CT 400/1A SINGLE-RATIO CLASS 0.2 S									
BURDEN 5VA STC 20kA FOR 1 SECOND,									
6 x 22kV OUTDOOR BUSHINGS *									
USED FOR COASTAL APPLICATIONS *									
ESKOM DRAWING No. D-DT-3118 *									
11	VARIOUS SAP NUMBERS CHANGED AND VA'S AN CT'S ON ALL REMAINING UNITS CHANGED AND SAP'S 0008726-27, 0175932-33,0180232-33, 0219348-53 REMOVED			P.A.T.	M.SHUTER	B.MWAREHWA	02.10.2012		
10	0180235 – CT RATIO CORRECTED			P.A.T.	B. MWAREHWA	V. SINGH	03.12.2010		
9	SHORT DESCRIPTIONS CORRECTED, SAP 0175938 – 0175941 REMOVED AND CORROSION + ESKOM SPEC CHANGED			N.M. P.A.T.	B. MWAREHWA	B. MWAREHWA	18.05.2009		
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	P. CROWDY	DATE:	16.03.1998	SCALE NTS			SAP No:		
CHKD:	D. PILLAY	DATE:	16.03.1998	CAD REF:			0216394		
				SERIES 3000			0216395		
DRAWN:	P.A. VERMAAK	DATE:	26.01.1998	FILE No:	D-DT-3118		SET	SHEET	REV
				3118			10	10	11