




CITY OF CAPE TOWN
ISIXEKO SASEKAPA
STAD KAAPSTAD

300G/2024/25 Clarification Meeting

High Voltage Circuits
Electricity Generation and Distribution

Making progress possible. **Together.**

300G/2024/25

SUPPLY AND DELIVERY OF HIGH VOLTAGE STRAIGHT JOINTS AND SPARE MATERIALS



**CITY OF CAPE TOWN
ISIXEKO SASEKAPA
STAD KAAPSTAD**

Outline

- Introduction
- Tender clarification by City of Cape Town
- Questions from Tenderers



CITY OF CAPE TOWN
ISIXEKO SASEKAPA
STAD KAAPSTAD

Introduction

- Non-compulsory meeting
- Emphasize certain key aspects of the tender and clarify areas of uncertainty. This is not a comprehensive discussion of the tender document.
- Unless a formal notice is issued by the CCT, the tender document is to be viewed as correct. Anything stated at the clarification meeting that could alter the tender document is therefore not enforced unless it is contained in a formal notice to tenderers.
- Closing date: 10 July 2025 @ 10:00

Tenderers must note that wherever the tender document refers to any particular trade mark, name, patent, design, type, specific origin or producer, such reference shall be deemed to be accompanied by the words “or equivalent”.



CITY OF CAPE TOWN
ISIXEKO SASEKAPA
STAD KAAPSTAD

Tender Clarification by City of Cape Town

Responsive Criteria

- The tender covers the supply and delivery of high voltage straight joints, link boxes, and spare materials. There are 79 items listed in the tender.
- Responsive criteria:
 - **Proof of accreditation from the OEM** (Original Equipment Manufacturer) that the tenderer is an accredited distributor of the products offered in Schedule F.13 (a).
 - **Schedule of type tests** completed for each item of equipment listed in **Schedule F.13 (b)**.
 - **Returnable Technical Schedules for cables, joints and terminations (Schedule F.13 (c))** are to be completed and returned with the submission of the tender offer or on request during evaluation of this tender.
 - For the purpose of evaluation tenderers must submit a set **of jointing instructions and technical details (assembly drawings) for each joint kit** tendered with the tender offer.



Tender Clarification by City of Cape Town

Information to Be Provided With the Tender

- **Proof of accreditation from the OEM** (Original Equipment Manufacturer) that the tenderer is an accredited distributor of the products offered in **Schedule F.13 (a)**. Proof in the form of a letter from the OEM must be submitted with the tender submission or on request during evaluation of this tender.
- **Schedule of type tests** completed for each item of equipment (**Schedule F.13 (b)**). Type Test certificates shall be appended to the tender submission or on request during evaluation of this tender.
- Returnable **Technical Schedules for cables, joints and terminations** (Schedule F.13 (c)).
- **Quality Assurance plan** (Schedule F.13 (d)).
- **Samples** of various items, such as paper tapes, may be requested from responsive tenderers at tender evaluation stage for the purpose of tender evaluation. Samples must be delivered to CCT at the tenderer's cost.
- All schedules listed above **MUST BE COMPLETED IN FULL**. Failure to do so may render the tender offer non-responsive

Tender Clarification by City of Cape Town

Pricing Assumptions

- Clause 5.6 – A rate is to be entered against each item in the Schedules of Rates.
 - An item against which no rate is/are entered, or if anything other than a rate or a nil rate (for example, a zero, a dash or the word “included” or abbreviations thereof) is entered against an item, it will also be regarded as a nil rate having been entered against that item, i.e. that there is no charge for that item. The Tenderer may be requested to clarify nil rates, or items regarded as having nil rates; and the CCT may also perform a risk analysis with regard to the reasonableness of such rates.
- If an item is considered to be obsolete and un-obtainable in the market, proof of such must be provided. CCT reserves the right to accept or reject the information provided.



Tender Clarification by City of Cape Town

Tender Conditions

- Detailed specification for each item is indicated in section C.5 of the tender document.
- The preferred delivery period for each item is indicated on the pricing schedule. Tenderers are required to indicate the actual delivery period for each item offered.
- Most of the City's HV infrastructure is equipped with CBI equipment and cabling, but the City accepts OEM approved and certified equivalent cables and material.
- The MV cable accessories will be exposed to very heavy pollution conditions with salt-laden atmosphere and high winds and the designs, where applicable, specific creepage distance must be to a minimum of 31mm/kV and products/materials shall be such as to ensure maximum protection against corrosion, tracking and erosion.
- A responsive tender is one that conforms to all the terms, conditions, and specifications of the tender documents without material deviation or qualification.
Thus, any proposed amendment to the terms and conditions detailed in the tender document will render a tender non-responsive.



Questions from Tenderers

- Floor is open for questions.



CITY OF CAPE TOWN
ISIXEKO SASEKAPA
STAD KAAPSTAD



CITY OF CAPE TOWN
ISIXEKO SASEKAPA
STAD KAAPSTAD

Thank You

Making progress possible. Together.